

LEGENDA



SPOLJNI VATROGASNI PUT



SMER EVAKUACIJE UNUTAR OBJEKTA

KORIDOR

KORIDOR ZA EVAKUACIJU



BROJ LJUDI U KORIDORU (10 LJUDI)



ULAZ U OBJEKT



UNUTRAŠNJI HIDRANT SA OPREMOM



SPOLJAŠNJI NADZEMNI HIDRANT




SPOLJAŠNJI PODZEMNI HIDRANT



STABILNI SISTEM ZA GAŠENJE POŽARA




RUČNI AP. ZA GAŠENJE POŽARA – PRAH OD 6 I 9 KG



PREVOZNI AP. ZA GAŠENJE POŽARA – PRAH OD 50 I 100 KG



RUČNI APARAT ZA GAŠENJE POŽARA – CO2 OD 5 KG



PREVOZNI AP. ZA GAŠENJE POŽARA – CO2 OD 10 I 30 KG



NUŽNA RASVETA



SISTEM RUČNE DOJAVE POŽARA



SISTEM AUTOMATSKE DOJAVE POŽARA




SIRENA ZA UZBUNU



CENTRALA SISTEMA AUTOMATSKE DOJAVE POŽARA



VATROOTPORNOST GRADJEVINSKOG ELEMENTA 120 MINUTA



VATROOTPORNOST VRATA 60 MINUTA



POVEĆANA OPASNOST OD EKSPLOZIJE



POVEĆANA OPASNOST OD POŽARA

I PS

OZNAKA POŽARNOG SEKTORA



RAZVODNI ELEKTRO ORMAR