

SKLADIŠNI REZERVOAR ZA NAFTNE DERIVATE

DIMENZIJE: 25000 mm ID x 15000 mm TH

TIP TANKVANE: ČAŠA U ČAŠI; DIMENZIJE: 30000 mm ID x 7500 mm TH



ALARMI I UPRAVLJANJE IZ SIGNALA

- 1 LSAH - 11 500 mm
LSAL - 700 mm

ESD BLOKADA SA PREKIDAČA NIVO

- 2 LSHH - 11 700 mm
- 3 LSLL - 650 mm

4. PAKETNA JEDINICA A-08; SISTEM ZA DRENIRANJE REZERVOARA, POSUDA PRIHVATA (SPUSTE IZ PSV, TSV NA CEVODODIMA I REZERVOARU NA LINJI DOVODA GORIVA U POSUDU. PREDVIDETI PRIKLJUČAK ZA FILTER-MEMBRAN TEST. IŠPUŠTANJE UZORKA IZ "VISIJAR" STAKLENE POSUDE SE VRŠI U DRENAŽNI TANK - ZATVOREN SISTEM UZORKOVANJA

This document and all technical details contained are exclusive property of the **owner** and must not be used nor published without the owner's written permission. Design was performed by CAD software and hand modifications are not allowed.

12769.SD-1-IDP-07-702  B


ED(1)/ED(2)/BMB5

12769.SD-1-IDP-01-705 

ED(1)/ED(2)/BMB5

KA PUMPAMA U PS-340/PS-341

Ovaj dokument, i svi tehnički detalji koje on sadrži, su ekskluzivno vlasništvo **Autodesk** i ne mogu se koristiti ili objavljivati bez njegove pismene saglasnosti.

1 0	01/2019	NA KOMENTAR INVESTITORU			LJK	LJK	MP		
Nr	DATUM / DATE	OPIS / DESCRIPTION			CRT / DRN	OVER. / CHKD	ODOB. / APPD		
INVESTITOR / OWNER: NIS a.d. NOVI SAD				NARUČILAC / CLIENT:					
OZNAKA I NAZIV DELA PROJEKTA / DESIGN PART SVESKA 7 - TEHNOLOGIJA					VRSTA TEH. DOK. / TYPE OF TECH. DOC. IDP				
PROJEKTAT / PROJECT:		PRETAKALIŠTE KAMIONSKIH CISTERNI							
OBJEKTAT / FACILITY:		TERMINAL ZA PRETOVAR I SKLADIŠTENJE NAFTNIH DERIVATA SMEDEREVO							
NAZIV CRTEŽA / DRAWING NAME									 POTPIS - PEČAT / SIGNATURE - SEAL
P&I DIJAGRAM REZERVOARA ZA SKLADIŠTENJE NAFTNIH DERIVATA; R-8									
DATUM / DATE	RAZMERA / SCALE	LIST / SHEET	BR. CRTEŽA / DRAWING NO.			CRTAO / DRAWN BY			
01.2019.		2/3	12769.SD-1-IDP-07-02.1			LJK			